LANDLORD/HOME OWNER GAS SAFETY RECORD Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998.



Certific	ate Refer	ence:	RB	3402															
DETAILS OF THE CONTRACTOR							DETAILS OF THE INSTALLATION						DETAILS OF THE CLIENT/LANDLORD						
Trading Title: Priority Home Service Limited						Installati		ented				Clie		West one let	tings				
Address:		Unit 4, Neepsend Triangle					Address:	83 E	83 Barber Road				Add	lress:	134 whitham road				
	1	1 Burton Road						She	ffield					ę	Sheffield				
		Sheffield																	
		Post Code: S3 8BW						Post Code: S101EB Post Cod							_{de:} S10) 2SR			
Gas Safe No:		539093 Telephone No: 0330 9991999					Telephone No:						Telephone No: 0114 2296823						
APPLIANCE DETAILS																			
	Location			Appliance Type					Make			Model		Flue Type	Landlord's Ap	pliance	ance Appliance Inspect		
1	Kitchen	chen		СНВ			Ideal				Logic + Combi 30 47-348-6		348-66	RS	Yes		Yes		
2																			
3																			
4																			
INSPECTION DETAILS													AUDI BLE CO ALARM						
	Combus Analys	yser in mbar or		Safety Devices(s) Ver Correct Operation		entilation Provision Satisfactory		Visual Condition of Flue and Termination		Performa	Flue formance Serviced		Jan Sale IO		Approved CO alarm fitted			esting of CO m satisfactory	
1	Readir 0006,9.9			Yes		Yes			actory ƏS	Test N/A			Use Yes		Yes			Yes	
2				100		100						100			100	100		100	
3																			
4																			
DEFE	ECT(S)	IDENTIFIE	D				F		L ACTI	<mark>on t</mark>	ΓΑΚΕΝ					r	IOTICE & LABEL		
1																			
2																			
3																			
4																			
Outcome of gas installation pipework visual inspection PASS Is the Er								nergency Control Valve access satisfactory YE					Out	utcome of gas tightness test PASS				PASS	
Outcome of gas supply pipework visual inspection PASS Is the Pro-							otective E	Equipoter	ntial bonding satisfactor			YES	NEXT INSPECTION DUE ON OR BEFORE: 15/12/20			2017			
SIGNATURES Report Issued By: Name: Rich Baker					n Baker		Signe	d:	(3°-		E	Date In:	spected:	15/12/2016	Gas ID	No:	3498362		
Report Received By: Name:								Signe	d:			C	Date Re	ceived:					

Report printed using Tysoft EasyGas - Copyright Tysoft 2016 - Gas Safety (Installation and Use) Regulations 1998

LANDLORD/HOME OWNER GAS SAFETY RECORD CHECK LIST

GUIDANCE FOR RECIPIENT (to be appended to the Certificate)

- 1. Check with the occupant to ascertain any problems with the gas installation and appliance(s).
- 2. Check that there is an adequate supply of air to all gas appliances.
- 3. Check the operation of appliance, control taps, ignition system and any flame supervision devices fitted.
- 4. Check the flame picture of any burner(s).
- 5. Check clearances from combustible materials e.g. kitchen cupboards etc.
- 6. Check the stability of the appliance (including provision of bracket or hook and chain on gas cookers).
- 7. Check gas installation pipe work and where appropriate any flexible connection(s).
- 8. Open-flues

(a) Check the condition and full route (where practicable) of the flue and, where applicable, the suitability of any terminal/chimney pot fitted.

(b) Check the appliance flue connection to any chimney or flue-liner. In the case of a back boiler installation, check all pipe ducts or voids entering the builder's opening including the annular space around any flue liner/flue connection are sealed.

(c) Carry out flue flow check.

(d) For a gas fire, check and clear the catchment space and check that any dampers have been removed or fixed in the open position.

(e) Test the appliance for spillage using any guidance given in the manufacturer's instructions.

9. Room - sealed appliances

(a) Check case and sight glass seal on appliance, replace as necessary.

(b) Check position of terminal, clearances from corners etc. vegetation and terminal guard fitted as appropriate.

- 10. Ensure the operating gas pressure or heat input rate or, where necessary, both are correct.
- 11. Test all controls to ensure satisfactory operation.
- 12. Test all disturbed gas connections for tightness using leak detection fluid, carry out full gas tightness test if required.
- 13. Advise the gas user of any defects/further work required or recommend as necessary.